

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/SZ/2022/ 630

Dated: 13/06/2022

FIRE SAFETY CERTIFICATE

Certified that **Kalgidhar National Public School**, located at Inderpuri, New Delhi-110012, having two wings namely Old wing and New wing. Old wing is comprised of ground plus two upper floors and New wing is comprised of ground plus three upper floors. was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2019/273 dated 04.02.2019. The School building was re-inspected by the officer concerned of Delhi Fire Service on 09.06.2022 in the presence of Sh. Surjeet Singh Sethi (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the school building is fit for occupancy class "**Educational**", with effect from the date of issue of this certificate for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010. printed below.

Issued on 13/06/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to:

1. The Principle. Kalgidhar National Public School, located at Inderpuri, New Delhi-110012.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.


CHAIRMAN
Kalgidhar National P


CHAIRMAN
Kalgidhar National P