



**DELHI JAL BOARD: GNCTD  
ZONAL LABORATORY WTP WAZIRABAD, DELHI-54**



**TEST REPORT**

Sample ID	Ref. No. D.J.B/DTQC/Wzd/2025-26/Paid-166-167		
Location /Address of Sample	Kalgidhar National Public School, Inderpuri, New Delhi-110012		
Letter Reference No.	KNPS/P-555/25-26	Ref. Letter Date	06.11.2025
Challan No.	192	Challan Date	07.11.2025
Sample Collection date	12.11.2025	Analysis start date	12.11.2025
Any other Information	--	Analysis end date	15.11.2025
		Reporting date	15.11.2025

**TEST RESULTS**

S.No	Parameters	Unit	As per the IS 10500		Inlet (from Supply)	Outlet (drinking tap)
			Acceptable limit	Permissible limit		
1	Colour	CU	5(Max)	15(Max)	2.0	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	4.2	2.6
4	pH Value at 27 °C	--	6.5-8.5	No relaxation	7.52	7.42
5	Electrical Conductivity	µS/cm	-	-	359	297
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	233	193
7	Total Alkalinity as CaCO <sub>3</sub>	mg/L	200(Max)	600(Max)	104	86
8	Total Hardness as CaCO <sub>3</sub>	mg/L	200(Max)	600(Max)	156	140
9	Calcium as Ca	mg/L	75(Max)	200(Max)	38	32
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	15	14
11	Iron as Fe	mg/L	1.0(Max)	No relaxation	0.08	0.06
12	Chloride as Cl	mg/L	250(Max)	1000(Max)	23	14
13	Fluoride as F	mg/L	1.0(Max)	1.5(Max)	0.31	0.30
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL	BDL
15	Nitrate as NO <sub>3</sub>	mg/L	45(Max)	No relaxation	5.7	5.1
16	Sulphate as SO <sub>4</sub>	mg/L	200(Max)	400(Max)	58	54
17	Residual Chlorine	mg/L	0.2(Min.)	1.0(Max)	0.80	0.70
18	Coliform Count at 37°(MPN)	/100 mL	Absent	No relaxation	0	0

\*BDL=Below Detection Limit

.....End of Report.....

**Remarks: Samples conform specification for the tested parameters and can be considered for drinking purpose.**

*[Signature]*  
Tested by  
Lab.Tech.

*[Signature]*  
Verified for Chemical parameters  
Asstt.Chemist

*[Signature]*  
Verified for MPN  
Bacteriologist

*[Signature]*  
Authorized by  
Chemist  
*[Signature]*

**ACWA(WZD)**

**Asstt. Chief Water Analyst  
D.J.B. (Govt. of N.C.T. of Delhi)  
Water Works, Wazirabad**

# KALGIDHAR NATIONAL PUBLIC SCHOOL

(English Medium) [ Recognised ]

Unaided Minority School

INDERPURI, NEW DELHI-110 012

PH.: 011-43570822


Email: knpschool@gmail.com,

Website: kanpsss.in, info@knpsss.in

Under the Management of

**Sri Guru Singh Sabha (Regd.)**

INDERPURI, NEW DELHI-110 012



Ref. No. KNPS/P-610/26-27

Date 06/04/2026

Deputy Health Officer  
North Delhi Municipal Corporation  
Public Health Department,  
Karol bag zone-110005

**Sub: Renewal of health Certificate.**

Sir,

Refer to the subject stated above this is to state that health certificate no: DHO/KBZ/2024/540, dated 19.07.2024 has expired kindly renew school health certificate.

The details of the school regarding this is given below:

Shift:

Timing of School: 08:00 am to 02:00 pm

Total No of Students: 1223

Boys: 771

Girls: 452

No. of Staff Members in school

Male: 13

Female: 51

No. of Rooms : 58

No. of Indian Toilet for Boys : 16

No. of Indian Toilet for Girls : 8

No. of Western Toilets for Boys: 2

No. of Western Toilets for Girls : 4

No. of Toilets for Male Staff : 1

No. of Toilets for Female Staff : 4

Copy of the previous health certificate dated 19.07.2024 is attached for your reference.

Thanks & Regards

HOS

CHAIRMAN